



**DATE COMPLETED:** \_\_\_\_\_ **QUALITY CHECK BY:** \_\_\_\_\_

**MH NUMBER:** \_\_\_\_\_ **STREET:** \_\_\_\_\_ **WR NUMBER:** \_\_\_\_\_

<i>CIRCLE ONE</i>		<i>DESCRIPTION</i>	<i>ACTION/NOTES</i>
YES	NO	MANHOLE COVER DAMAGE	_____
YES	NO	MANHOLE RING UNSECURED/DAMAGED	_____
YES	NO	MANHOLE LABEL MISSING ON RING	_____
YES	NO	EXCESSIVE SEDIMENT IN MANHOLE	_____
YES	NO	GROUND ROD MISSING - QTY _____	_____
YES	NO	CABLE RACKS NOT BONDED TO GROUND RING	_____
YES	NO	CABLE ARMS/INSULATORS MISSING - QTY _____	_____
YES	NO	ASBESTOS PRESENT - APPROX. FOOTAGE _____	_____
YES	NO	INSPECT SPLICES FOR SWELLING _____	_____
YES	NO	INSPECT SECONDARY CABLES FOR OPENS _____	_____
YES	NO	CIRCUITS NOT LABELED - QTY _____	_____
YES	NO	CABLES NOT RACKED - CIRCUITS _____	_____
YES	NO	CABLES NOT GROUNDED - CIRCUITS _____	_____
YES	NO	CABLE LEAKING - CIRCUITS _____	_____
YES	NO	FIRE TAPE/FOAM MISSING - CIRCUITS _____	_____
YES	NO	ANODE(S) MISSING (2 REQUIRED) - QTY _____	_____
YES	NO	MANHOLE ROOF AND WALLS DEFICIENT - DESCRIBE _____	_____
YES	NO	MANHOLE VIEW CORRECT - IF INCORRECT, MAKE CORRECTIONS ON MANHOLE VIEW	_____
		CONDUIT SIZE	_____

**ADDITIONAL COMMENTS:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_